

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0412:002 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Reed National/Phillips Aire, 7301 International Dr., Holland OH 43528
Contact: *Chuck Schneider (419) 865-5000

DESIGN: Model PHILLIPS 3FD and 4FD series. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's anme, model number and UL label.

APPROVAL: Listed as a 1½-hour fire-rated damper.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage dampers.

*Rev. 08-23-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

AUGUST 19, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager